

Alkalinity (total, as CaCO3)		Criteria	
02/27/2020	27.9 mg/L		
Aluminum (total)		Criteria	
02/27/2020	0.0006 mg/L	<=0.1	Operational - Conventional
Arsenic (total)		Criteria	
02/27/2020	0.0002 mg/L	<=0.010	MAC
Barium (total)		Criteria	
02/27/2020	0.0001 mg/L	<=1	MAC
Cadmium (total)		Criteria	
02/27/2020	0.00004 mg/L	<=0.005	MAC
Chloride		Criteria	
02/27/2020	1.8 mg/L	<=250	AO
Chromium (total)		Criteria	
02/27/2020	0.0001 mg/L	<=0.05	MAC
Colour		Criteria	
02/27/2020	5 CU	<=15	AO
Copper (total)		Criteria	
02/27/2020	0.0002 mg/L	<=1.0	AO
Cyanide (free)		Criteria	
02/27/2020	< 0.001 mg/L	<=0.2	MAC
Fluoride		Criteria	
02/27/2020	< 0.1 mg/L	<=1.5	MAC
Hardness (total, as CaCO3)		Criteria	
02/27/2020	36.7 mg/L		
Iron (total)		Criteria	
02/27/2020	0.005 mg/L	<=0.3	AO
Lead (total)		Criteria	
02/27/2020	0.00001 mg/L	<=0.005	MAC
Manganese (total)		Criteria	
02/27/2020	0.0001 mg/L	<=0.02	AO

Mercury (total)		Criteria	
02/27/2020	0.00001 mg/L	<=0.001	MAC
Nitrate (as NO3)		Criteria	
02/27/2020	0.08 mg/L	<=45	MAC
pH		Criteria	
02/27/2020	7.30	>=7.0, <=10.5	Operational Guideline
Selenium (total)		Criteria	
02/27/2020	0.0003 mg/L	<=0.05	MAC
Sodium (total)		Criteria	
02/27/2020	2.1 mg/L	<=200	AO
Sulfate		Criteria	
02/27/2020	12 mg/L	<=500	AO
Total Dissolved Solids / TDS		Criteria	
02/27/2020	< 10 mg/L	<=500	AO
Total Organic Carbon / TOC		Criteria	
02/27/2020	6.2 mg/L		
Total Suspended Solids / TSS		Criteria	
02/27/2020	4 mg/L		
Total Trihalomethanes / TTHM		Criteria	
02/27/2020	NT mg/L	<=0.100	MAC
Uranium (total)		Criteria	
02/27/2020	< 0.00001 mg/L	<=0.02	MAC
Zinc (total)		Criteria	
02/27/2020	0.0004 mg/L	<=5	AO

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown

* Indicates Criteria is exceeded

Alkalinity (total, as CaCO3)		Criteria	
09/22/2020 00:00	< 2.0 mg/L		
Aluminum (total)		Criteria	
* 09/22/2020 00:00	2.90 mg/L	<=0.1	Operational - Conventional
Arsenic (total)		Criteria	
09/22/2020 00:00	0.00016 mg/L	<=0.010	MAC
Barium (total)		Criteria	
09/22/2020 00:00	0.0642 mg/L	<=1	MAC
Cadmium (total)		Criteria	
09/22/2020 00:00	0.0000418 mg/L	<=0.005	MAC
Chloride		Criteria	
09/22/2020 00:00	11.3 mg/L	<=250	AO
Chromium (total)		Criteria	
09/22/2020 00:00	< 0.00010 mg/L	<=0.05	MAC
Colour		Criteria	
09/22/2020 00:00	< 2.0 CU	<=15	AO
Copper (total)		Criteria	
09/22/2020 00:00	0.0152 mg/L	<=1.0	AO
Fluoride		Criteria	
09/22/2020 00:00	0.070 mg/L	<=1.5	MAC
Hardness (total, as CaCO3)		Criteria	
09/22/2020 00:00	124 mg/L		
09/22/2020 00:00	125 mg/L		
Iron (total)		Criteria	
09/22/2020 00:00	0.050 mg/L	<=0.3	AO
Lead (total)		Criteria	
09/22/2020 00:00	0.000422 mg/L	<=0.005	MAC
Manganese (total)		Criteria	
09/22/2020 00:00	0.0120 mg/L	<=0.02	AO

Mercury (total)		Criteria	
09/22/2020 00:00	< 0.0000050 mg/L	<=0.001	MAC
pH		Criteria	
* 09/22/2020 00:00	5.10	>=7.0, <=10.5	Operational Guideline
Selenium (total)		Criteria	
09/22/2020 00:00	0.000134 mg/L	<=0.05	MAC
Sodium (total)		Criteria	
09/22/2020 00:00	11.2 mg/L	<=200	AO
Sulfate		Criteria	
09/22/2020 00:00	142 mg/L	<=500	AO
Total Dissolved Solids / TDS		Criteria	
09/22/2020 00:00	202 mg/L	<=500	AO
Total Organic Carbon / TOC		Criteria	
09/22/2020 00:00	3.0 mg/L		
Total Trihalomethanes / TTHM		Criteria	
09/22/2020 00:00	0.0181 mg/L	<=0.100	MAC
Uranium (total)		Criteria	
09/22/2020 00:00	0.000129 mg/L	<=0.02	MAC
Zinc (total)		Criteria	
09/22/2020 00:00	0.0041 mg/L	<=5	AO

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown

* Indicates Criteria is exceeded

Alkalinity (total, as CaCO₃)		Criteria	
09/14/2020 11:00	97.8 mg/L		
Aluminum (total)		Criteria	
09/14/2020 11:00	0.0895 mg/L	<=0.1	Operational - Conventional
Arsenic (total)		Criteria	
09/14/2020 11:00	0.00032 mg/L	<=0.010	MAC
Barium (total)		Criteria	
09/14/2020 11:00	0.0211 mg/L	<=1	MAC
Cadmium (total)		Criteria	
09/14/2020 11:00	< 0.0000050 mg/L	<=0.005	MAC
Chloride		Criteria	
09/14/2020 11:00	16.4 mg/L	<=250	AO
Chromium (total)		Criteria	
09/14/2020 11:00	0.00019 mg/L	<=0.05	MAC
Colour		Criteria	
09/14/2020 11:00	< 5.0 CU	<=15	AO
Copper (total)		Criteria	
09/14/2020 11:00	0.00264 mg/L	<=1.0	AO
Fluoride		Criteria	
09/14/2020 11:00	0.225 mg/L	<=1.5	MAC
Hardness (total, as CaCO₃)		Criteria	
09/14/2020 11:00	149 mg/L		
Iron (total)		Criteria	
09/14/2020 11:00	0.209 mg/L	<=0.3	AO
Lead (total)		Criteria	
09/14/2020 11:00	0.00252 mg/L	<=0.005	MAC
Manganese (total)		Criteria	
09/14/2020 11:00	0.00458 mg/L	<=0.02	AO
Mercury (total)		Criteria	
09/14/2020 11:00	< 0.0000050 mg/L	<=0.001	MAC

pH		Criteria
09/14/2020 11:00	8.40	>=7.0, <=10.5 Operational Guideline
Selenium (total)		Criteria
09/14/2020 11:00	< 0.000050 mg/L	<=0.05 MAC
Sodium (total)		Criteria
09/14/2020 11:00	12.8 mg/L	<=200 AO
Sulfate		Criteria
09/14/2020 11:00	46.5 mg/L	<=500 AO
Total Dissolved Solids / TDS		Criteria
09/14/2020 11:00	204 mg/L	<=500 AO
Total Organic Carbon / TOC		Criteria
09/14/2020 11:00	5.32 mg/L	
Total Suspended Solids / TSS		Criteria
09/14/2020 11:00	< 3.0 mg/L	
Uranium (total)		Criteria
09/14/2020 11:00	0.00105 mg/L	<=0.02 MAC
Zinc (total)		Criteria
09/14/2020 11:00	0.101 mg/L	<=5 AO

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded



Total Trihalomethanes / TTHM		Criteria	
* 01/14/2020 13:47	0.120 mg/L	<=0.100	MAC
* 01/21/2020 13:26	0.101 mg/L	<=0.100	MAC
* 04/01/2020 13:49	0.122 mg/L	<=0.100	MAC
* 07/07/2020	0.128 mg/L	<=0.100	MAC

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown

> means greater than upper detection limit shown

« means detected & less than number shown

» means detected & greater than number shown

* Indicates Criteria is exceeded

Alkalinity (total, as CaCO3)		Criteria	
09/09/2020 09:00	67.9 mg/L		
Aluminum (total)		Criteria	
09/09/2020 09:00	0.0088 mg/L	<=0.1	Operational - Conventional
Arsenic (total)		Criteria	
09/09/2020 09:00	0.0003 mg/L	<=0.010	MAC
Barium (total)		Criteria	
09/09/2020 09:00	0.0401 mg/L	<=1	MAC
Cadmium (total)		Criteria	
09/09/2020 09:00	< 0.00004 mg/L	<=0.005	MAC
Chloride		Criteria	
09/09/2020 09:00	6.2 mg/L	<=250	AO
Chromium (total)		Criteria	
09/09/2020 09:00	< 0.0001 mg/L	<=0.05	MAC
Colour		Criteria	
09/09/2020 09:00	5 CU	<=15	AO
Copper (total)		Criteria	
09/09/2020 09:00	0.0035 mg/L	<=1.0	AO
Cyanide (free)		Criteria	
09/09/2020 09:00	< 0.005 mg/L	<=0.2	MAC
Fluoride		Criteria	
09/09/2020 09:00	< 0.1 mg/L	<=1.5	MAC
Hardness (total, as CaCO3)		Criteria	
09/09/2020 09:00	85.8 mg/L		
Iron (total)		Criteria	
09/09/2020 09:00	< 0.005 mg/L	<=0.3	AO
Lead (total)		Criteria	
09/09/2020 09:00	< 0.0001 mg/L	<=0.005	MAC
Manganese (total)		Criteria	
09/09/2020 09:00	0.0004 mg/L	<=0.02	AO

Mercury (total)		Criteria	
09/09/2020 09:00	< 0.00001 mg/L	<=0.001	MAC
Nitrate (as NO3)		Criteria	
09/09/2020 09:00	NT mg/L	<=45	MAC
pH		Criteria	
09/09/2020 09:00	8	>=7.0, <=10.5	Operational Guideline
Selenium (total)		Criteria	
09/09/2020 09:00	< 0.0003 mg/L	<=0.05	MAC
Sodium (total)		Criteria	
09/09/2020 09:00	6.99 mg/L	<=200	AO
Sulfate		Criteria	
09/09/2020 09:00	17 mg/L	<=500	AO
Total Dissolved Solids / TDS		Criteria	
09/09/2020 09:00	126 mg/L	<=500	AO
Total Organic Carbon / TOC		Criteria	
09/09/2020 09:00	4.1 mg/L		
Total Suspended Solids / TSS		Criteria	
09/09/2020 09:00	< 3 mg/L		
Total Trihalomethanes / TTHM		Criteria	
09/09/2020 09:00	< 0.005 mg/L	<=0.100	MAC
Uranium (total)		Criteria	
09/09/2020 09:00	0.0004 mg/L	<=0.02	MAC
Zinc (total)		Criteria	
09/09/2020 09:00	0.0007 mg/L	<=5	AO

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

< means less than lower detection limit shown
 > means greater than upper detection limit shown
 « means detected & less than number shown
 » means detected & greater than number shown

* Indicates Criteria is exceeded

Alkalinity (total, as CaCO3)		Criteria	
09/30/2020 15:00	9.6 mg/L		
Aluminum (total)		Criteria	
* 09/30/2020 15:00	0.130 mg/L	<=0.1	Operational - Conventional
Arsenic (total)		Criteria	
09/30/2020 15:00	0.00031 mg/L	<=0.010	MAC
Barium (total)		Criteria	
09/30/2020 15:00	0.00191 mg/L	<=1	MAC
Cadmium (total)		Criteria	
09/30/2020 15:00	0.0000050 mg/L	<=0.005	MAC
Chloride		Criteria	
09/30/2020 15:00	8.03 mg/L	<=250	AO
Chromium (total)		Criteria	
09/30/2020 15:00	0.00184 mg/L	<=0.05	MAC
Copper (total)		Criteria	
09/30/2020 15:00	0.00472 mg/L	<=1.0	AO
Fluoride		Criteria	
09/30/2020 15:00	< 0.020 mg/L	<=1.5	MAC
Hardness (total, as CaCO3)		Criteria	
09/30/2020 15:00	8.58 mg/L		
Iron (total)		Criteria	
09/30/2020 15:00	0.024 mg/L	<=0.3	AO
Lead (total)		Criteria	
09/30/2020 15:00	0.000057 mg/L	<=0.005	MAC
Manganese (total)		Criteria	
09/30/2020 15:00	0.00191 mg/L	<=0.02	AO
Mercury (total)		Criteria	
09/30/2020 15:00	< 0.0000050 mg/L	<=0.001	MAC

pH		Criteria	
* 09/30/2020 15:00	6.81	>=7.0, <=10.5	Operational Guideline
Selenium (total)		Criteria	
09/30/2020 15:00	< 0.000050 mg/L	<=0.05	MAC
Sodium (total)		Criteria	
09/30/2020 15:00	6.87 mg/L	<=200	AO
Total Dissolved Solids / TDS		Criteria	
09/30/2020 15:00	38 mg/L	<=500	AO
Total Organic Carbon / TOC		Criteria	
09/30/2020 15:00	8.5 mg/L		
Total Suspended Solids / TSS		Criteria	
09/30/2020 15:00	< 3.0 mg/L		
Total Trihalomethanes / TTHM		Criteria	
* 09/30/2020 15:00	0.131 mg/L	<=0.100	MAC
Uranium (total)		Criteria	
09/30/2020 15:00	0.000080 mg/L	<=0.02	MAC
Zinc (total)		Criteria	
09/30/2020 15:00	0.0349 mg/L	<=5	AO

Result Legend:

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no,
 TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

* Indicates Criteria is exceeded