

<b>Alkalinity (total, as CaCO<sub>3</sub>)</b>		<b>Criteria</b>	
10/27/2021 08:55	60.5 mg/L		
<b>Aluminum (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	0.0205 mg/L	<=0.1	Operational - Conventional
<b>Arsenic (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	0.00032 mg/L	<=0.010	MAC
<b>Barium (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	0.0256 mg/L	<=1	MAC
<b>Cadmium (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	< 0.0000050 mg/L	<=0.005	MAC
<b>Chloride</b>		<b>Criteria</b>	
10/27/2021 08:55	6.44 mg/L	<=250	AO
<b>Chromium (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	< 0.00050 mg/L	<=0.05	MAC
<b>Colour</b>		<b>Criteria</b>	
10/27/2021 08:55	< 5.0 CU	<=15	AO
<b>Copper (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	< 0.00050 mg/L	<=1.0	AO
<b>Fluoride</b>		<b>Criteria</b>	
10/27/2021 08:55	0.090 mg/L	<=1.5	MAC
<b>Hardness (total, as CaCO<sub>3</sub>)</b>		<b>Criteria</b>	
10/27/2021 08:55	74.5 mg/L		
<b>Iron (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	0.012 mg/L	<=0.3	AO
<b>Lead (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	< 0.000050 mg/L	<=0.005	MAC
<b>Manganese (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	0.00051 mg/L	<=0.02	AO
<b>Mercury (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	< 0.0000050 mg/L	<=0.001	MAC

<b>pH</b>		<b>Criteria</b>	
10/27/2021 08:55	7.99	>=7.0, <=10.5	Operational Guideline
<b>Selenium (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	0.000051 mg/L	<=0.05	MAC
<b>Sodium (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	5.57 mg/L	<=200	AO
<b>Sulfate</b>		<b>Criteria</b>	
10/27/2021 08:55	15.6 mg/L	<=500	AO
<b>Total Dissolved Solids / TDS</b>		<b>Criteria</b>	
10/27/2021 08:55	96 mg/L	<=500	AO
<b>Total Organic Carbon / TOC</b>		<b>Criteria</b>	
10/27/2021 08:55	1.80 mg/L		
<b>Total Suspended Solids / TSS</b>		<b>Criteria</b>	
10/27/2021 08:55	< 3.0 mg/L		
<b>Total Trihalomethanes / TTHM</b>		<b>Criteria</b>	
10/27/2021 08:55	0.0080 mg/L	<=0.100	MAC
<b>Uranium (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	0.000323 mg/L	<=0.02	MAC
<b>Zinc (total)</b>		<b>Criteria</b>	
10/27/2021 08:55	< 0.0030 mg/L	<=5	AO

**Result Legend:**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

\* Indicates Criteria is exceeded

<b>Alkalinity (total, as CaCO3)</b>		<b>Criteria</b>	
09/30/2021 09:00	71.8 mg/L		
<b>Aluminum (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	0.0064 mg/L	<=0.1	Operational - Conventional
<b>Arsenic (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	0.00026 mg/L	<=0.010	MAC
<b>Barium (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	0.0380 mg/L	<=1	MAC
<b>Cadmium (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	< 0.0000050 mg/L	<=0.005	MAC
<b>Chloride</b>		<b>Criteria</b>	
09/30/2021 09:00	6.67 mg/L	<=250	AO
<b>Chromium (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	< 0.00050 mg/L	<=0.05	MAC
<b>Colour</b>		<b>Criteria</b>	
09/30/2021 09:00	< 5.0 CU	<=15	AO
<b>Copper (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	0.00278 mg/L	<=1.0	AO
<b>Fluoride</b>		<b>Criteria</b>	
09/30/2021 09:00	0.069 mg/L	<=1.5	MAC
<b>Hardness (total, as CaCO3)</b>		<b>Criteria</b>	
09/30/2021 09:00	80.0 mg/L		
<b>Iron (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	< 0.010 mg/L	<=0.3	AO
<b>Lead (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	< 0.000050 mg/L	<=0.005	MAC
<b>Manganese (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	0.00041 mg/L	<=0.02	AO
<b>Mercury (total)</b>		<b>Criteria</b>	
09/30/2021 09:00	< 0.0000050 mg/L	<=0.001	MAC

pH		Criteria
09/30/2021 09:00	7.96	>=7.0, <=10.5 Operational Guideline
Selenium (total)		Criteria
09/30/2021 09:00	0.000153 mg/L	<=0.05 MAC
Sodium (total)		Criteria
09/30/2021 09:00	6.44 mg/L	<=200 AO
Sulfate		Criteria
09/30/2021 09:00	17.6 mg/L	<=500 AO
Total Dissolved Solids / TDS		Criteria
09/30/2021 09:00	111 mg/L	<=500 AO
Total Organic Carbon / TOC		Criteria
09/30/2021 09:00	4.02 mg/L	
Total Suspended Solids / TSS		Criteria
09/30/2021 09:00	< 3.0 mg/L	
Total Trihalomethanes / TTHM		Criteria
09/30/2021 09:00	0.0042 mg/L	<=0.100 MAC
Uranium (total)		Criteria
09/30/2021 09:00	0.000376 mg/L	<=0.02 MAC
Zinc (total)		Criteria
09/30/2021 09:00	< 0.0030 mg/L	<=5 AO

**Result Legend:**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

\* Indicates Criteria is exceeded

<b>Alkalinity (total, as CaCO3)</b>		<b>Criteria</b>	
10/06/2021 13:35	42.8 mg/L		
<b>Aluminum (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	< 0.0030 mg/L	<=0.1	Operational - Conventional
<b>Arsenic (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	0.00012 mg/L	<=0.010	MAC
<b>Barium (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	0.0154 mg/L	<=1	MAC
<b>Cadmium (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	< 0.0000050 mg/L	<=0.005	MAC
<b>Chloride</b>		<b>Criteria</b>	
10/06/2021 13:35	1.98 mg/L	<=250	AO
<b>Chromium (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	< 0.00050 mg/L	<=0.05	MAC
<b>Colour</b>		<b>Criteria</b>	
10/06/2021 13:35	< 5.0 CU	<=15	AO
<b>Copper (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	0.00077 mg/L	<=1.0	AO
<b>Fluoride</b>		<b>Criteria</b>	
10/06/2021 13:35	0.045 mg/L	<=1.5	MAC
<b>Hardness (total, as CaCO3)</b>		<b>Criteria</b>	
10/06/2021 13:35	41.1 mg/L		
<b>Iron (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	< 0.010 mg/L	<=0.3	AO
<b>Lead (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	< 0.000050 mg/L	<=0.005	MAC
<b>Manganese (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	0.00078 mg/L	<=0.02	AO
<b>Mercury (total)</b>		<b>Criteria</b>	
10/06/2021 13:35	< 0.0000050 mg/L	<=0.001	MAC

pH		Criteria
10/06/2021 13:35	7.78	>=7.0, <=10.5 Operational Guideline
Selenium (total)		Criteria
10/06/2021 13:35	< 0.000050 mg/L	<=0.05 MAC
Sodium (total)		Criteria
10/06/2021 13:35	1.82 mg/L	<=200 AO
Sulfate		Criteria
10/06/2021 13:35	0.58 mg/L	<=500 AO
Total Dissolved Solids / TDS		Criteria
10/06/2021 13:35	49 mg/L	<=500 AO
Total Organic Carbon / TOC		Criteria
10/06/2021 13:35	1.64 mg/L	
Total Suspended Solids / TSS		Criteria
10/06/2021 13:35	< 3.0 mg/L	
Total Trihalomethanes / TTHM		Criteria
10/06/2021 13:35	0.0263 mg/L	<=0.100 MAC
Uranium (total)		Criteria
10/06/2021 13:35	< 0.000010 mg/L	<=0.02 MAC
Zinc (total)		Criteria
10/06/2021 13:35	< 0.0030 mg/L	<=5 AO

**Result Legend:**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

\* Indicates Criteria is exceeded



<b>Alkalinity (total, as CaCO3)</b>	<b>Criteria</b>		
11/17/2021 15:43	61.0 mg/L		
<b>Aluminum (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	0.0033 mg/L	<=0.1	Operational - Conventional
<b>Arsenic (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	0.00021 mg/L	<=0.010	MAC
<b>Barium (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	0.0267 mg/L	<=1	MAC
<b>Cadmium (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	< 0.0000050 mg/L	<=0.005	MAC
<b>Chloride</b>	<b>Criteria</b>		
11/17/2021 15:43	7.57 mg/L	<=250	AO
<b>Chromium (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	< 0.00050 mg/L	<=0.05	MAC
<b>Colour</b>	<b>Criteria</b>		
11/17/2021 15:43	< 5.0 CU	<=15	AO
<b>Copper (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	0.00083 mg/L	<=1.0	AO
<b>Fluoride</b>	<b>Criteria</b>		
11/17/2021 15:43	0.092 mg/L	<=1.5	MAC
<b>Hardness (total, as CaCO3)</b>	<b>Criteria</b>		
11/17/2021 15:43	74.1 mg/L		
<b>Iron (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	< 0.010 mg/L	<=0.3	AO
<b>Lead (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	< 0.000050 mg/L	<=0.005	MAC
<b>Manganese (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	0.00122 mg/L	<=0.02	AO
<b>Mercury (total)</b>	<b>Criteria</b>		
11/17/2021 15:43	< 0.0000050 mg/L	<=0.001	MAC

pH		Criteria
11/17/2021 15:43	7.97	>=7.0, <=10.5 Operational Guideline
Selenium (total)		Criteria
11/17/2021 15:43	< 0.000050 mg/L	<=0.05 MAC
Sodium (total)		Criteria
11/17/2021 15:43	4.88 mg/L	<=200 AO
Sulfate		Criteria
11/17/2021 15:43	17.2 mg/L	<=500 AO
Total Dissolved Solids / TDS		Criteria
11/17/2021 15:43	101 mg/L	<=500 AO
Total Organic Carbon / TOC		Criteria
11/17/2021 15:43	2.32 mg/L	
Total Suspended Solids / TSS		Criteria
11/17/2021 15:43	< 3.0 mg/L	
Total Trihalomethanes / TTHM		Criteria
11/17/2021 15:43	0.0024 mg/L	<=0.100 MAC
Uranium (total)		Criteria
11/17/2021 15:43	0.000290 mg/L	<=0.02 MAC
Zinc (total)		Criteria
11/17/2021 15:43	< 0.0030 mg/L	<=5 AO

**Result Legend:**

P=present, A=absent, PR=presumptive, ND=non-detect, OR=over-range, OG=overgrown, Y=yes, N=no, TNTC=too numerous to count, NR=no result, NT=not tested, IG=ignore, ER=external report, SC=see comment

- < means less than lower detection limit shown
- > means greater than upper detection limit shown
- « means detected & less than number shown
- » means detected & greater than number shown

\* Indicates Criteria is exceeded

