



### WATER TREATMENT PLANT WEEKLY LOG SHEET

This form must be faxed to (867) 669-7517 or emailed to [environmental\\_health@gov.nt.ca](mailto:environmental_health@gov.nt.ca) each week.

Testing for the Week of:	<b>Weekly Water Testing Instructions</b> 1. Minimum free chlorine residual of 0.2mg/L (ppm) after 20 minutes of contact time <ul style="list-style-type: none"> <li>• Most plants will require higher free chlorine to maintain adequate residual throughout the distribution system</li> <li>• Truck fill plants without treated water storage should maintain a free chlorine residuals of 0.4mg/L (ppm) after 20 minutes of contact time</li> </ul> 2. Test free chlorine residual three (3) times a day from a tank or truck after 20 minutes of contact time 3. Record raw water turbidity once (1) a day 4. Record treated water turbidity three (3) times per day
Community Name:	

Date/Time	Monday			Tuesday			Wednesday			Thursday			Friday			Saturday			Sunday		
Free chlorine mg/L (ppm) Range 0.2-2.4																					
Total Chlorine mg/L (ppm) Range 0.2-2.4																					
Raw Water Turbidity (NTU) <5 Raw																					
Treated Water Turbidity (NTU)																					
Completed by: (Name)																					

Comments/Observations:

Operator Name:	Email:	Telephone Number:
----------------	--------	-------------------